

Waste2GridS (826161) Publishable Summary

Waste-to-Energy for grid balancing services via gasification and RSOC

Ligang Wang

North China Electric Power University



**Converting WASTE to offer flexible GRID balancing Services with highly-integrated, efficient solid-oxide plants
(Theoretical investigation)**


Duration: 2019.01-2020.12

Budget: 528750 €

**Coordinator: Ligang Wang (ligang.wang@epfl.ch)
Jan Van herle (jan.vanherle@epfl.ch)**

**Officer: Antonio Aguilo-Rullan
antonio.aguilo-rullan@fch.europa.eu**

A new potential service from biowastes



❑ Biomass/biowaste can potentially participate grid balancing for high penetration of renewable energy sources (RES), given **enhanced efficiency, reduced cost and increased utilization rate**

❑ One plant **capable of switching between electricity and methane production** can enable high annual utilization and cost reduction **by sharing major components**


Solid-oxide cell (SOC) technology

The most suitable syngas conversion technology for biomass utilization


RES power




SOEC mode




Chemicals



SOFC mode




Power



- High temperature (650-850C), heat integration with gasif. process
- High efficiency at a potentially low cost due to no use of noble metal
- High fuel flexibility with no poisoning impact of CO/CO₂: syngas as fuel for SOFC mode, syngas-to-methane via H₂ from SOEC
- Reversible operation with flexible switch between fuel cell mode (power generation) and electrolysis mode (power storage)

Waste2GridS concept

Triple-mode grid-balancing plant by integrating biomass gasification & SOC




- ❑ **Non-stop, highly-efficient, full-load** operation for high annual operation hours, i.e., theoretically 365 x 24h with no stand-by mode

- ❑ Potentially-large **investment reduction** due to key component sharing and syngas-to-methane **with no carbon capture**

Waste2GridS realization


The coordination of two stack blocks enables the realization of three modes



❑ **Constant operation** of biomass processing, syngas production/cleaning

❑ Mode switch by coordinating stack blocks, BoP and methanation reactor

Economic evaluation for 2030




Main factors affecting economic feasibility of W2G plants:

- Grid-balancing service (energy balancing & capacity reserves)
- Plant design, performance & operation
- Chemical onsite storage and trade
- Biomass supply cost

Theoretical grid flexibility needs 2030



Flexibility-need prediction via historical data and energy development plans




❑ Capacity wise, three RES dominated zones has significant UP and DOWN regulation needs, reaching **several to even tens of GW level**

❑ Energy wise, three zones present **annual excess electricity of 5-17 TWh**, to be addressed by multiple flexibility means, e.g., cross-country transmission, traditional fossil plants and **new flexibility capacities**

Waste availability 2030



Waste availability predicted via biomass databases, GIS & EU directives



- Total energy of **theoretical** grid flexibility needs is at the same magnitude of the energy of local available waste and biomass
- Since actual W2G contribution will be much less than the theoretical value, local waste & biomass is sufficient to drive W2G for grid services

Plant design

Multi-objective optimal plant design considering multiple degrees of freedom: technology combination, key component specifications and heat integration



$$\eta_{PowGen} = \frac{\text{Net power produced}}{\text{biom energy in}}$$

$$\eta_{PowSto} = \frac{\text{LHV energy of CH}_4}{\text{Biom energy in} + \text{net elec. in}}$$

$$\eta_{PowNeu} = \frac{\text{LHV energy of CH}_4}{\text{Biom energy in}}$$

❑ **A set of optimal designs** with trade-off performances obtained

❑ **High efficiency** enabled for all modes: PowGen & PowSto efficiencies much higher than state-of-the-art single-mode systems, PowNeu mode as an efficient productive alternative of non-productive stand-by mode

Plant CAPEX threshold/real



Plant CAPEX levelized to reference stack enabling one indicator for three modes

$$\text{Plant CAPEX threshold} = \frac{\textit{Maximum possible profit of all plants installed}}{\textit{number of reference stacks of all plants installed}}$$


$$\text{Plant CAPEX real} = \frac{\textit{Evaluated plant CAPEX of all plants installed}}{\textit{number of reference stacks of all plants installed}}$$

reference stack: a stack with 5120 cm² active area

- Plant CAPEX real < threshold, likely economically feasible
- Plant CAPEX real > threshold, likely economically infeasible

Economic feasibility identification

Plant CAPEX threshold and real evaluated for 40 case studies in DK and IT



Key economic assumptions

- Reference energy balancing price 40 €/MWh
- Reference payback time 5 years
- Stack lifetime: 5-year continuous operation
- Synthesis natural-gas price: 0.8 €/kg
- Annual cell production volume > 50,000 m²

❑ Economic feasibility enhanced by increased annual PowGen&PowSto hours. Feasible business cases when **annual PowGen&PowSto operation for over 3500 hours**.

❑ Economic feasibility mainly affected by grid-service gain and biomass supply cost. Plants below 100 MW_{th_biomass} are feasible, while 100–1000 MW_{th} plants become not feasible due to biomass supply.

Key conditions for economic feasibility





Given current market circumstances, W2G concept could be feasible if stack costs have significant cost reduction

Plant scales	100 MWth biomass feed ≈60 MWe PowGen power ≈160 MWe PowSto power
Payback time	5 years
Balancing price	40 €/MWh
Stack lifetime	5 years
SNG selling price	0.8 €/kg
PowGen&PowSto hours	> 3500
Stack costs	< 1600 €/kWe-SOFC

Scaling up strategy

The method of plant scale-up from kW-level to MW-level plant?



Key conclusions



- ❑ Large grid flexibility needs in DK and IT-SUD in 2030
- ❑ Local biomass sufficient to contribute significantly to grid balancing
- ❑ W2G concept enables **highly-efficient grid-balancing service**
- ❑ Given current grid-balancing prices, methane price and stack lifetime, economical feasible case studies exist with the conditions:
 - ❑ Single plant scale: biomass feed of up to a few hundreds of MW_{th} , PowGen power up to 100 MWe, PowSto power up to a few hundreds of MWe
 - ❑ **PowGen&PowSto hours: > 3500 hours**
 - ❑ **Stack costs: < 1600 €/kWe-SOFC**



Acknowledgement:

This project has received funding from the Fuel Cells and Hydrogen Joint Undertaking under grant agreement No 826161.

This Joint Undertaking receives support from the European Union's Horizon 2020 research and innovation programme, Hydrogen Europe and Hydrogen Europe research.

